

CFP Standard 2 Zone Conventional Fire Alarm Panel

Part No. **CFP702-4**



Overview

Certified to EN54 parts 2, 4 and 13, C-TEC's CFP 2 zone conventional fire alarm panel offers an array of user and installer-friendly features at a very competitive price. Supplied in an attractive flush or surface mountable plastic enclosure, it includes two detector zones, four conventional sounder circuits, class change and alert inputs, on-board fire and fault relays and combined keypad/keyswitch entry. A wide range of engineering functions are also provided including selectable zone delays, coincidence and non-latching zone facilities. Comprehensive test and fault finding facilities are also provided. Optional repeaters and relay expansion boards also available.



More Information

- Third-party certified to EN54 parts 2 and 4 by the Loss Prevention Certification Board (LPCB) and EN54 part 13 certified by Kiwa Tefelcation.
- Intuitive user-friendly interface with colour-coded buttons and combined keypad/keyswitch entry.
- Manufactured by C-TEC in the UK.
- Two detector zone circuits.
- Four conventional sounder circuits*
- Integral 1.5A EN54-4/A2 compliant switch mode PSU.
- Wide range of engineering functions including zone test, coincidence, zone delay and non-latching zones.
- Two on-board relays (Fire and Fault).
- Two open-collector outputs (Remote and Reset).
- 'Class change' and alert inputs.
- Installer-friendly design.



- Attractive flush or surface mountable plastic lid and enclosure - no bezel required.
- Low 25mA quiescent current.
- Multiple indicators.
- System expansion connections provided for up to eight two-wire repeaters (one CFP761 network card required per system) and optional CFP relay boards.
- Space for two x 12V 3.3Ah VRLA batteries.
- Fully compatible with C-TEC's ActiV fire detectors, sounders and visual alarm devices.

Technical Specifications

| | |
|--------------------------------------|--|
| Approvals/certifications | Certified to EN54 Parts 2 & 4 by the LPCB., Certified to EN54-13 by Kiwa Telefication. |
| Mains supply | 230V 50/60Hz. |
| Mains rated current | 350mA maximum. |
| Internal power supply | 19V-28.5V (27V nominal). Ripple 7V maximum (battery fault). |
| Total output current limited to | 1.5A @ 230Vac (ImaxA eq 146mA). |
| Quiescent current | 25mA (mains failed, internal sounder active, PSU & gen fault LED lit) |
| Max battery size and type | 2 x 12V 3.2Ah VRLA connected in series. Min. battery size 1.2Ah. |
| No. of detector zone circuits | 2 (Max. length per circuit is 500m). |
| Call point resistor value | 470 to 680Ω. |
| Max. devices per detector zone | 25 detectors (or 32 detectors/manual call points combined). |
| No. of conventional sounder circuits | 4 (Max. length per circuit is 500m). |
| EOL resistor value | 6800Ω 5% Tol. 0/25W (blue, grey, red, gold). |
| Alarm voltage | 27V max, 20V min (final battery voltage) |
| Max. sounder output current | 4 x 200mA (800mA total). |
| Auxiliary relays | Two: (1) Aux. Fire; (2) Fault. Volt free single pole changeover. Max. switch current 1A; Max. switch voltage 30Vdc. |
| Open collector outputs | Two: (1) Reset (Active during reset cycle); (2) Remote (Active during any unsilenced fire condition provided all relevant delays have expired). Max. sink current 30mA, Max. open circuit voltage 24V Aux. Power (Protected by a resettable fuse. 100mA min. hold current. Resets when fault removed). |
| Other outputs | Two: (1) 'Class Change' (constant sounders); (2) Alert (pulsed sounders). Connect to 0V to trigger, Max. input voltage 27V (non-latching) |
| Auxiliary inputs | Program coincidence (double knock); Invoke One Man Walk Test; Program delays; Set up zones for non-latching operation; Program sounders to resound (or not resound) when a new zone enters al |
| Engineer (AL3) functions | Yes - for optional network driver cards (one required per repeater system), relay output cards and EN54-13 sounder circuit interface boards. |
| Expansion connections | 380 W x 235 H x D 96mm (hole required for flush mounting = 367 W x 220 H x 75 D mm. No bezel required). |
| Product dimensions (mm) | Plastic lid and base; RAL7035 textured |
| Construction & finish | IP30. |
| IP Rating | 1.75kg (without batteries) |
| Weight | -5°C to +40°C. Max relative humidity: 95%. |
| Operating conditions/temperature | |



T 01942 322744 E sales@c-tec.co.uk
F 01942 829867 W www.c-tec.com



C-TEC, Challenge Way, Martland Park, Wigan, WN5 0LD United Kingdom